



The School District of Osceola County, Florida

Blaine A. Muse - Superintendent

817 Bill Beck Boulevard • Kissimmee, Florida 34744-4495
Phone: (407) 870-4600 • Fax: (407) 870-4010 • www.osceola.k12.fl.us

March 26, 2007

ADDENDUM NO.: 4

(To be attached and become a part of Call For Bids.)

Rental of Type II-B, Relocatable Classrooms

BID NO.: SDOC 07-077NM

THOMAS E. CHALIFOUX
DISTRICT NO. 2 KISSIMMEE
PHONE: (407) 846-0977

TOM GREER
DISTRICT NO. 4 KISSIMMEE
PHONE: (407) 892-8200

JOHN MCKAY
DISTRICT NO. 5 ST. CLOUD
PHONE: (407) 957-4056

DAVID E. STONE
DISTRICT NO. 3 KISSIMMEE
PHONE: (407) 933-2700

JAY WHEELER
DISTRICT NO. 1 KISSIMMEE
PHONE: (407) 390-0505

Due date of proposals is March 28, 2007, at 2:00 p.m., at the School District of Osceola County, 817 Bill Beck Blvd., Building 2000, Purchasing Office, Kissimmee, Florida.

This Addendum is being issued to clarify areas, statements, requests, and specifications in the original document that the District felt needed an extra explanation or to answer questions that have been proposed by prospective bidders.

#1 Add the following paragraph to the bid package of SDOC 07-077 NM: Transaction Fee:

A transaction fee of one (1.0) percent of the total dollar amount of each purchase shall apply to any and all purchases from this Bid/Contract to other entities purchasing [renting] items herein specified and awarded. The awarded vendor(s) shall report each month, using the District's Transaction Fee form, any and all financial activities relating to this bid/contract; e.g., transactions to eligible entities to purchase [rent] from this bid/contract. Failure to comply with this requirement shall constitute grounds for declaring the vendor in default. Vendors delinquent in paying the Transaction Fee may be excluded from conducting future business with the School Board.

#2 Reference Addendum #2:

- i. Item #3 (i) – Q. Will the District consider alternates to the paperless gypsum board that was specified for the internal walls?
A. No.
- ii. Item #4 (a) – Q. Our Building uses a 1-hour fire rated wall assembly with steel panel. Is this an acceptable substitute?
A. Bidders are requested to bid the box that is specified. [See 3 (c) – “alternates or equals are not acceptable”].
- iii. Item #3 (1) states that “all walls need “one-hour” fire rating. Q. Is that a true statement?
A. All exterior walls shall be 1 hour rated.



Board Meets First Tuesday of Each Month

DISTRICT-WIDE ACCREDITATION BY THE SOUTHERN ASSOCIATION OF COLLEGES AND SCHOOLS

An Equal Opportunity Agency

ADDENDUM NO.: 4
Rental of Type II-B, Relocatable Classrooms
BID NO.: SDOC 07-077NM

Acknowledgment of Addendum by Vendor:

This addendum shall be completed by Vendor and returned with the Bid Package. If a bid package has already been submitted, this addendum must be submitted to the above address in a sealed envelope, which is marked on the outside: addendum to Bid, bid title and number.

This is to acknowledge receipt of this addendum, which becomes part of the bid, a document.

NAME

TITLE

SIGNATURE

COMPANY'S NAME

DATE