

**Roof Coating Projects at Hickory Tree Elementary, Lakeview Elementary, Mill
Creek Elementary, Pleasant Hill Elementary and Parkway Middle School**
Bid # SDOC-07-107-LK

Addendum #1
June 7, 2007
Page 1 of 2

This addendum is issued to clarify, add, delete, correct and/or change the contract documents to the extent indicated and is hereby made a part of the above noted contract documents on which the contract will be based. Any modifications/changes made by this addendum affect only the portions or paragraphs specifically identified herein; all remaining portions of the proposal to remain in force. It is the responsibility of all bidders to conform to this addendum. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject Bidder to Disqualification.

1. REF: SECTION 02070-3 – 1.7.B **DELETE.**
2. REF: SECTION 07542-1 – 1.01.B **CHANGE.** SECTION 01330 - SUBMITTAL PROCEDURES
3. REF: SECTION 07542-1 – 1.01.F **DELETE.**
4. REF: SECTION 07542-1 – 1.01.G **DELETE.**
5. REF: SECTION 07542-3 – 1.05.A **CHANGE.** SECTION 01330 - SUBMITTAL PROCEDURES
6. REF: SECTION 07542-4 – 1.13.A **DELETE.**
7. REF: SECTION 07592-2 – 3.1.A **CHANGE.** SECTION 07591 -
PREPARATION FOR REROOFING AND COATING
8. REF: SECTION 07592-2 – 3.2.A **CHANGE.** SECTION 07591 -
PREPARATION FOR REROOFING AND COATING
9. REF: SECTION 07561-1 – 1.4.C **CHANGE.** Color shall be chosen by the Owner from coating manufacturer's standard color chart.
10. REF: SECTION 07561-2 – 1.5.A. **CHANGE.** The Bidder shall be a Florida Certified Roofing Contractor Licensed company who has been a certified or approved contractor for one or more of the approved coating manufacturers for a minimum of 5 years. The Bidder shall have **5 year company history** of completing coating projects with one or more of the approved manufacturers with evidence not more than **12 months old** from the coating manufacturer of current certified or approved applicator status. **Bidder shall submit with the Bid satisfactory evidence of applicator status and company experience.**
11. REF: SECTION 07561-4 – 3.2.A.2. **CHANGE.** Power wash entire existing metal roof utilizing potable water with a maximum pressure of 3,000 psi as required to clean down to a bondable surface.

**Roof Coating Projects at Hickory Tree Elementary, Lakeview Elementary, Mill
Creek Elementary, Pleasant Hill Elementary and Parkway Middle School**
Bid # SDOC-07-107-LK

Addendum #1

June 7, 2007

Page 2 of 2

12. REF: SECTION 07561-5 – 3.2.A.4. **ADD.** . . with Simple Green detergent **if required** in accordance. . .
13. REF: SECTION 07561-7 – 3.7D. **NEW.** Use primer and coating products from the above approved manufacturers as recommended by the manufacturer to meet the manufacturer's 10 year warranty specification.
14. REF: SECTION 07561-3 – 2.1.A.2.a **CHANGE.** Republic Powered Metals, Inc. "**SOLARGARD**"
15. REF: SECTION 07561-3 – 2.1.A.3 **CHANGE.** The drawings are based on "**SOLARGARD**".....
16. REF: SECTION 07561-7 – 3.7.B.1 **CHANGE.** Primer : **SOLARGARD Metal Primer.**

END OF ADDENDUM #1