

BID # SDOC-09-B-093 CJ

May 4, 2009

ADDENDUM NO.: 1 (To be attached and become a part of the Bid)

A/C FILTERS

To be opened, **May 13, 2009** at 2:00 p.m., in the School District of Osceola County, Purchasing Office, 817 Bill Beck Boulevard, Kissimmee, Florida 34744.

The original Invitation To Bid (ITB) documents shall remain in full force and effect, except as modified herein, and shall take precedence over any contrary provisions in the prior documents. If you have any questions regarding this Addendum please feel free to contact Cheryl Jessee, Senior Buyer by email at jesseec@osceola.k12.fl.us or by phone at (407) 870-4627.

This addendum is being issued to correct information provided in the bid document.

On page 4, Section 1.03 B add:

The filters shall have a minimum efficiency reporting value (MERV) of 8 when evaluated under ASHRAE Standard 52.2-2007. They shall have a MEERV-A of 8 when evaluated under Appendix J of the same Standard.

On page 5, Section 1.03 C add:

Provide product laboratory test report for each depth listed including all details as prescribed in ASHRAE Standard 52.2 – 2007 including Appendix J. Date of the tests must be within the last two (2) years.

On page 5, Section 1.03 D add:

The filter shall have a minimum efficiency reporting value (MERV) of 14 when evaluated under ASHRAE Standard 52.2 – 2007. They shall have a MERV-A of 14 when evaluated under Appendix J of the same Standard. Provide product laboratory test report for each depth listed including all details as prescribed in ASHRAE Standard 52.2 – 2007 including Appendix J. Date of the tests must be within the last two (2) years.

On page 5, Section E change to read:

Provide one (1) filter sample of each of the following sizes:

24 X 24 X 1

24 X 24 X 2

13 X 27 1/2 X 1

24 X 24 X 12

To correct a couple errors on the Price Sheet and add some omitted filter sizes the price sheet has been revised. **Remove the original price sheet and replace with the Revised Price Sheet dated 5/4/09. See Attachment 2 the Revised Price Sheet.**

Acknowledgement of Addendum #1 by Vendor:

This addendum shall be completed by Vendor and returned with the Bid Package. If the Bid package has already been submitted, this addendum must be submitted to the above address in a sealed envelope, which is marked on the outside Addendum to Bid, Bid title and number.

This is to acknowledge receipt of this addendum, which will become part of the Bid document.

AUTHORIZED NAME (TYPED)

TITLE

AUTHORIZED SIGNATURE

COMPANY NAME