

BID # SDOC-09-P-033-CJ

November 7, 2008

ADDENDUM NO.: 2

(To be attached and become a part of the RFP)

WATER TREATMENT FOR COOLING TOWERS & CLOSED LOOP SYSTEMS

To be opened, November 13, 2008 at **2:00 P.M.**, in the School District of Osceola County, Purchasing Office, 817 Bill Beck Boulevard, Kissimmee, Florida 34744.

Clarifications:

Throughout the RFP document there are several places that states, RFP #SDOC **08**-P-033 CJ, the correct RFP # is SDOC **09**-P-033 CJ.

On Page 8, for Tab 8 it says "Financial Statement – (Weighted Value – 5)", it should say Financial Statement – (Weighted Value 5). It is not -5.

Questions submitted in accordance with Section 3.07 of the RFP.

Question:

What are the current water treatment expenditures?

Answer:

The 2007-2008 School year we spent approximately \$34,000.00 with the current company.

Question:

What is the cost of water and sewer in each district?

Answer:

Charges for water and sewer vary according to utility and threshold limits of consumption. Go to www.tohowater.com www.ouc.com and www.enterprisecdd.org

Question:

Is the blow down metered? If not, how are sewer charges evaluated?

Answer:

Sewer deduct meters are present at all cooling towers.

Question:

Is there a portion of the capital budget that is allocated for replacement of chillers, towers, and/or tower fill? If so, what % of the budget is set aside for this purpose?

Answer:

On an as needed basis.

Question:

What is the average life span currently being achieved for chillers, towers and tower fill?

Answer:

The average life span is; Chillers 10 to 15 years, Cooling Towers 10 to 12 years, and Fill 10 to 12 years.

Question:

The price sheet lists the following schools as having more than one cooling tower: Horizon Middle; Michigan Ave. Elementary; Osceola High; St. Cloud High. Are the towers for each of these schools are on a common sump, or if the sumps are separate?

Answer:

Sumps are separate.

Question:

Can you list which schools, if any, have bromine feeders installed in order to use bromine as a biocide? In schools that do not have a bromine feeder, are other biocide options allowed?

Answer:

None, we do not have any algae problems.



Acknowledgement of Addendum by Vendor:

This addendum shall be completed by Vendor and returned with the RFP Package. If the RFP package has already been submitted, this addendum must be submitted to the above address in a sealed envelope, which is marked on the outside Addendum to RFP, RFP title and number.

This is to acknowledge receipt of this addendum, which will become part of the RFP document.

AUTHORIZED NAME (TYPED)

TITLE

AUTHORIZED SIGNATURE

COMPANY NAME