


- GENERAL NOTES:**
1. THE INDICATED PIPE ROUTING WAS DEVELOPED FROM THE BEST INFORMATION AVAILABLE, BUT MAY NOT BE ACCURATE. THE CONTRACTOR SHALL PROVIDE LOCATING SERVICES TO DETERMINE ACTUAL PIPE ROUTING PRIOR TO EXCAVATION.
 2. THE EXISTING UNDERGROUND CHWS&R PIPING IS PVC AND TRANSITIONS TO STEEL NEAR THE EXTERIOR WALL OF EACH BUILDING ENTRANCE. THE PVC PIPING SHALL BE REPLACED WITH STEEL PIPING. FIELD VERIFY THE EXACT LOCATION THE PVC TO STEEL CONNECTION OCCURS.
 3. PROVIDE SECTION DEMOLITION OF PIPING INDICATED WITH HATCHING. CHW PIPING NOT HATCHED MAY BE ABANDONED IN PLACE IF IT DOES NOT INTERFERE WITH THE NEW PIPE INSTALLATION.

Mechanical Demolition Plan - Site Piping
 SCALE: 1" = 30'-0"


Construction Documents - 04/29/2009

Sheet Title
Mechanical Demolition Plan Site Piping
 Number
M2.01



SABISTON ENGINEERING GROUP, INC.
 8212 EARLWOOD AVE • MT DORA, FL 32757
 P: 352.383.5525 • F: 352.383.5572
 WWW.SABISTONENGINEERING.COM
 STATE OF FLORIDA CERTIFICATE NO. 9811
 SEG PROJECT NO. 09001

Engineer of Record
 Donald J. Sabiston, P.E., State of Florida No. 54889



Project

**Discovery Middle School
 Chilled Water Piping Replacement**

Owner

School District of Osceola County Florida

Revisions

| Number | Description |
|--------|-------------|
| | |
| | |
| | |
| | |