

# THE SCHOOL DISTRICT OF OSCEOLA COUNTY, FLORIDA

## Purchasing/Property Records/Warehouse

817 Bill Beck Boulevard, Building 2000 • Kissimmee • Florida 34744-4492

Phone: 407-870-4630 • Fax: 407-870-4616 • [www.osceola.k12.fl.us](http://www.osceola.k12.fl.us)

Superintendent of Schools

Michael A. Grego, Ed.D.

### SCHOOL BOARD MEMBERS

- District 1 – Jay Wheeler  
407-390-0505
- District 2 – Marjorie Guillen-Melendez  
407-922-5113
- District 3 – Cindy Lou Hartig  
407-832-3999
- District 4 – David Stone, Vice Chair  
407-957-4056



June 8, 2010

### ITB # SDOC 10-B-098 CJ Covered Play Structure for Osceola High School Addendum # 1

The original Invitation to Bid (ITB) documents shall remain in full force and effect, except as modified herein, and shall take precedence over any contrary provisions in the prior documents. The Bid Submittal deadline is Tuesday, June 15, 2010 at 2:00 PM. This addendum is being issued to answer questions submitted.

Question 1: Can you please verify size of shelter. When enlarged they become blurry.

Answer 1: See Separately Posted Attachment C, the measurements are 120' X 100'. When posted separately it is clear when you enlarge.


Question 2: There are no specifications for electrical, it is noted on the plans, do we bid the electrical also?

Answer 2: Yes, this is a total turnkey project. Originally indicated 12 light fixtures however to match existing lighting configuration this project will include: sixteen (16) 400 W Metal Halide High Bay Light Fixtures (4 per bay), and four (4) 2-lamp 8' Fluorescent strip fixtures (1 per bay). All lighting shall be 120 Volt. The power for this covered play structure will be pulled from the existing neighboring covered play structure approximately 30' away see Attachment B - A-0.0.1 Site Plan.

Question 3: Do you have any Structural drawings or any information regarding load requirements for the building.  
Question 3: Separately attached, is Attachment I - S-1.0.1 FOUNDATION PLAN.

If you should have any questions regarding this addendum, please do not hesitate to contact Cheryl M. Jessee, the Purchasing Agent responsible for this project at [jesseec@osceola.k12.fl.us](mailto:jesseec@osceola.k12.fl.us) or by phone at 407-870-4627.

Sincerely,

  
Cheryl L. Olson, CPPO, C.P.M., CPM, FCCN  
Director of Purchasing and Warehouse Services

CLO/cmj

#### Acknowledgment of Addendum #1 by Vendor:

This addendum shall be completed by the Vendor and returned with the submittal. If submittal has already been submitted, this addendum must be submitted to the above address in a sealed envelope, which is marked on the outside: Addendum to ITB, ITB title and number.

This is to acknowledge receipt of this addendum, which will become part of the ITB document.

\_\_\_\_\_  
NAME (TYPED OR PRINTED)

\_\_\_\_\_  
TITLE

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
VENDOR NAME

\_\_\_\_\_  
DATE

\_\_\_\_\_  
PHONE NUMBER

*Student Achievement – Our Number One Priority*

Districtwide Accreditation by the Southern Association of Colleges and Schools

School District Main Office: 817 Bill Beck Boulevard • Kissimmee • Florida • 34744-4492 • Phone: 407-870-4600 • [www.osceola.k12.fl.us](http://www.osceola.k12.fl.us)

An Equal Opportunity Agency